

# OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : March 30, 2022

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 4/21/2022**

---

- For the month of February, the Wastewater Treatment Facility had one exceedances of its N.P.D.E.S. permit NTU. It was caused by a cracked board on the digester supernatant board allowing solids to be returned to the influent. The daily average limit is 2 and on February 23<sup>rd</sup> it was at 2.07. The leak has since been fixed.
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station: Staff has been checking all equipment at the Rio Del Oro lift station on a regular basis. The blower unit on the mini phoenix is temporarily down to have the carbon tank fixed then it will be put back on. Staff is in talks with a company that has a biological feed system that claims it can reduce the odors in the collection system. They will be giving the District a sixty day free trial of their system. After that period, the District can decide if it meets its needs and keep using or have them take the system away.
- Looking for the I & I problems within the collection system has been put on hold because of short Staff and the work load of inspections for the District.
- The two Collections workers hired are working hard to obtain there class A or B license. Staff are training them and Collections will soon be back to full force on cleaning and taking care of the system better.
- Staff is looking at purchasing an electric Utility truck for the Plant and going through Sourcewell Member pricing.
- Estimated Plant processed for the month of February was 33.1 MG.