

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : June 26, 2026

TO : John Tillotson, General Manager

FROM: Nicholas Pomeroy, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 7/16/2026**

- For the month of May the OPUD Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit.
- Plant Staff cleaned the filters and the UV system to keep both systems running efficiently.
- We have ordered a longer power cable for the third pump at Lift Station 14. A new Grundfos Pump has been ordered & delivered for Lift Station 2. Landscaping work around the lift stations is being completed.
- Collection Staff Jetted approximately 0ft of sewer main and used the CCTV van to camera approximately 2,500ft of sewer main. The Vac-Con was down for maintenance and repairs. It was fixed on 6/23/26 and is back in proper working order.
- The Gold Village waste water plant has been running smoothly. We have provided Yuba County with a couple of quotes to have a valve replaced and also start working on a UV upgrade as the current system is obsolete now.
- The Hard Rock casino waste water plant has been running well. The UV lamps have been replaced (yearly maintenance). The parts for the anoxic mixer have been ordered and should be shipping the first week of July. The HMI screen for the screw press was replaced with a new screen. The SCADA computer is being setup and programmed by Telstar and should be up and running within the next month.
- The OPUD Waste Water Plant processed during the month of May 62.30 million gallons, which is an average of 2.01 MGD flow.
- Collection Staff have completed the majority of FOG inspections for the year. We are still waiting to complete 3 schools.
- All of the Drying Beds have been filled for the second time. In May one bed was filled and the remaining six were filled in June.

Lift Station Status

Lift Station 1 – 3 Vaughan Pumps (10 Horsepower); All in service

Lift Station 2 – 1 Vaughan Pump (10 Horsepower) and 1 Grundfos Pump has been installed; The Grundfos Pump that was installed 9-17-25 got something lodged in the impeller and broke it. The new impeller is installed and as of 2/23/26 the Pump is back in the Lift Station and ready to be used.

Lift Station 3 – 2 Vaughan Pumps (5 Horsepower); All in service

Lift Station 4 – Out of Service

Lift Station 5 – 2 Vaughan Pumps (5 Horsepower); All in service

Lift Station 6 – 2 Vaughan Pumps (10 Horsepower); 1 Pump is out of service

Lift Station 7 – 2 Pumps normal operation. Currently 1 Vaughan (10 Horsepower) in service & we are in the process of installing a Grundfos (2 Horsepower) pump as the second pump.

Lift Station 8 – 2 Vaughan Pumps (10 Horsepower); 1 Pump is out of service

Lift Station 9 – 1 Flygt Pump (3 Horsepower); All in service

Lift Station 10 – 1 Vaughan Pump (5 Horsepower); All in service

Lift Station 11 – 2 Vaughan Pumps (10 Horsepower); All in service

Lift Station 12 – 2 Vaughan Pumps (40 Horsepower); All in service

Lift Station 13 – 2 Vaughan Pumps (7.5 Horsepower); All in service

Lift Station 14 – 3 Vaughan Pumps (75 Horsepower); 2 in service. The 1 Grundfos pump was delivered on 2/19/26 and we are working with our electrician to get it installed. Guide Rails and discharge piping has been replaced for all 3 pumps.

Lift Station 15 – 2 Vaughan Pumps (40 Horsepower); All in service

Lift Station 16 – 2 Vaughan Pumps (50 Horsepower); 1 in service. The second pump that was down has been repaired. We are working with our electrician to get all new electrical panels installed so we are able to get the second pump up and running.

Lift Station 17 – 2 Vaughan Pumps (5 Horsepower); All in service

Lift Station 18 – 2 Vaughan Pumps (5 Horsepower); All in service

Lift Station 19 – 2 Vaughan Pumps (5 Horsepower); All in service

Lift Station 20 – 2 Vaughan Pumps (5 Horsepower); All in service

Lift Station 27 – 2 Vaughan Pumps (50 Horsepower); All in service

If you have any questions my contact info is below.

Nicholas Pomeroy

Chief Plant Operator
Olivehurst Public Utility District
Cell (530) 635-8113
email: npomeroy@opud.org