

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : August 26, 2022

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 8/18/2022**

- For the month of August, the Wastewater Treatment Facility had two exceedances of its N.P.D.E.S. permit. Total coliform of 46 MPN on 7/7, this was believed to be caused by particles in the water after cleaning the UV system and restarting the system back-up to quickly. Also, a 7.8 MPN on 7/20, this is an unknown cause none of the system's numbers were out of range. Both cause seven-day median exceedances in the Permit.
- Plant Staff installed new filter panels in the filters and cleaned the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; Staff has been checking all equipment at Rio Del Oro lift station on a regular basis.
- The odor control project for lift station 14 (Zanes and River Oaks) was started on July 14th. It has hit a snag. The company is extending the trial because the H2s reading went all the way back to the original test result. They are working on finding what's gone wrong.
- Staff has had to put work into looking for I&I problems with the collection system on hold because of short Staff and workload on doing inspections for the District.
- Estimated Plant processed for the month of August was 42.8 MG.

If you have any questions my contact info is below.

Gregory P. Axline

Chief Plant Operator
Olivehurst Public Utility District
Phone (530) 743-0843
Cell (530) 812-2270
email: gaxline@opud.org