

# OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : May 23, 2024

TO : John Tillotson, General Manager

FROM: Nicholas Pomeroy, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 6/20/2024**

---

- For the month of April the OPUD Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit.
- Plant Staff cleaned the filters and the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station: Staff has been checking all equipment at Rio Del Oro lift station on a regular basis.
- The bar screen has been running for just over 3 months now. There haven't been any issues since the bar screen has been repaired.
- Lift Station 14: Staff has been water flushing bi-weekly at lift station 14. Staff has also been doing a caustic flush on a monthly basis to help alleviate the hydrogen sulfide. Staff is also testing and recording the hydrogen sulfide numbers 2-3 times a week.
- We have received the Camera Van back from U-Rock with the new camera system installed. Staff has had on site training with the new CCTV setup. We have ordered the upgraded version of the WinCan software to go along with the new camera system. We are working on scheduling a 2 day training on the software. Collection staff will start using the new system to inspect the sewer lines in Olivehurst first.
- Gold Village waste water plant has been running smoothly. There were no violations in April.
- The Hard Rock casino waste water plant has been running without any issues. The polymer pump for the screw press has been fixed and the casino has been notified to order more polymer since we just started to use the last drum.
- One new wastewater operator has started work and another will be starting by the end of the month.
- The OPUD Waste Water Plant processed during the month of April 55.88 million gallons, which is an average of 1.86 MGD flow.

**If you have any questions my contact info is below.**

## Nicholas Pomeroy

Chief Plant Operator  
Olivehurst Public Utility District  
Phone (530) 743-0843  
Cell (530) 635-8113  
email: [npomeroy@opud.org](mailto:npomeroy@opud.org)