

# OLIVEHURST PUBLIC UTILITY DISTRICT

## MEMORANDUM



DATE : September 30, 2021

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 10/21/2021**

---

- For the month of August the Wastewater Treatment Facility had two exceedances of its N.P.D.E.S. permit

First the filter effluent had a 12NTU (permit limit is 10) caused by an illegal discharge we believe to be the wine storage company that discharges to lift station 8. We are in the process with them to add to their discharge system so that this won't happen again.

Second exceedance was a 2.25 seven day median the permit limit is 2.2. Possibly caused by the illegal discharge.

- For the month of September the Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; Staff has been check all equipment at Rio Del Oro lift station on a regular basis. The blower unit on the mini phoenix is been taken off line to be worked on and is will be back up and running soon.
- Staff has had to put work into looking for I&I problems with the collection system on hold because of short Staff and work load on doing inspections for the District.
- We have hired one Collections worker and expect to hire another Collections worker soon.
- Bay alarm has turned the system back on and given us time to look for another alternative security system. Staff is looking into a new company for a new system and have one that will do a demo at the committee meeting.
- Estimated Plant processed for the month of August was 38.1 MG.
- Estimated Plant processed for the month of September was 38.57 MG.