

OLIVEHURST PUBLIC UTILITY DISTRICT

December 28th, 2020

To: John Tillotson

From Virgil Willard

Re: Monthly Report of Activities

1. Water Treatment Plants / Wells

WTP #4 / well#1 No operating issues. Dec. total 0.248 MG

WTP #28 / well #10 No operating issues. Nov. total 0.0 MG

Wheeler Ranch WTP well #29 and #30 No operating issues Dec. total 40.006 MG.

Lindhurst Booster Pump Station No operating issues.

Plumas Lake WTP well #31 and well #32. No operating issues. Dec. total 5.102 MG

WTP #34. The plant is back on line for the month of November with no operating issues.
DEC. total 19.842 MG

2.

Total MG	2013	2014	2015	2016	2017	2018	2019	2020
Jan.	48.5	62.0	50.5	44.8	60.2	49.5	49.3	52.7
Feb.	48.8	47.3	47.0	43.3	42.4	47.2	48.8	
March	52.2	56.6	76.2	48.6	50.5	51.2	52.9	74.2
April	78.1	81.2	77.8	72.2	53.6	65.1	70.0	93.8
May	177.5	144.9	102.5	104.7	121.5	116.9	104.3	142.2
June	175.5	169.7	113.3	139.8	142.2	151.8	151.5	165.4
July	193.1	188.7	126.4	156.5	170.3	171.4	168.3	186.9
Aug.	225.6	166.3	117.2	146.3	161.0	152.1	170.9	176.9
Sept.	216.4	134.4	97.6	130.9	134.1	131.2	136.8	145.0
Oct.	163.7	105.5	88.1	88.7	110.5	105.2	117.2	132.3
Nov.	117.0	56.0	44.0	52.6	58.2	80.7	91.2	83.3
Dec.	836.7	53.8	46.4	49.3	51.7	53.5	60.5	65.198

The pumping report will be a month behind.

3.

Water Wells	Static Nov.	Static Dec.	Op. Nov.	Op. Dec.	Setting
Well #1	32ft	28ft	48ft	48ft	140ft
Well #4	31ft	31ft	50ft	52ft	140ft
Well #10	27ft	26ft	44ft	52ft	160ft
Well #28	39ft	28ft	54ft	36ft	200ft
Well #29	38ft	29ft	121ft	172ft	252ft
Well #30	50ft	29ft	121ft	105ft	190ft
Well #31	50ft	28ft	128ft	121ft	200ft
Well #32	48ft	26ft	124ft	118ft	180ft
Well #34	21ft	28ft	46ft	34ft	200ft

4. For the month of December 2020 the distribution system and water treatment plants met all requirements.

5. Water Distribution Rep

1390 high noon repair service leak

4896 Tulsa Ave repair service leak

1656 Stepney way repair meter setter

6. Radio Read Meters

0 GPS corrects needed

4 flow checks evaluated and discussed with customers

2 touch couplers repaired

76 locations on Non Consumption list repaired as necessary

11 MXU replaced (11 x \$160.00)= \$1,760

24 registers replaced (24 x \$72.00)= \$1,728.00

2 chambers replaced (2 x \$40.00)= \$80.00

The above is a list of repairs/expenditures recognizing failure after the monthly meter read.

December meter repair \$4,288. The meter expenditure will be an addition to all Water Department monthly reports.

7. Meter Program 408 flat rate services.

8. Water service shut off for non-payment on hold.

9. District Subdivision and other projects
 - a. December finals Plumas Lake 23
 - 1242 Abroso way –lennar ,john
 - 1234 Abroso way ---Lennar,john
 - 1068, 1072,1076 Monterey---Cresleigh doyal
 - 2098,2100,forbes lennar john
 - 1091,1098,Ballentine lennar,john
 - 1304, 1314, 1322, 1330, heartlands, deardo, dr.horton
 - b. December final Olivehurst 0