

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : February 28, 2019

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 3/21/2018**

- For the month of February the Wastewater Treatment Facility had an exceedances three different days for UV transmittance and one day for NTU of its permit. This was caused by the large storm that came through on the February 3rd, 4th and the 13th, 14th and 15th. The plant ran the whole month having all systems running well and efficiently the storm caused the exceedances.
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; There has been no complaints since the carbon filters on the mini phoenix were replaced to try and help with possible odors from it. We also started adding a floating degreaser that has a strong citrus odor to it to help with possible odors from the wet well.
- Staff has started to put more work into looking for I&I problems with the collection system. They have found several and we are addressing them as we find them.
- Estimated Plant processed for the month of February was 77.56 MG.