

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : May 31, 2019

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 6/20/2019**

- For the month of April the Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit.
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; There has been no complaints since the carbon filters on the mini phoenix were replaced to try and help with possible odors from it. We also started stocking up on deodorizer for the mister, getting ready for the summer. Staff does check all equipment at Rio Del Oro lift station on a regular basis. New carbon filter have been purchased and ready to be put in first sign of any odors.
- Staff has started to put more work into looking for I&I problems with the collection system. They have found several and we are addressing them as we find them. Currently we are looking into different types of repair systems for fixing some of the I & I issues.
- Estimated Plant processed for the month of April was 68.5 MG.