

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : July 26, 2019

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 8/15/2019**

- For the month of July the Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit.
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; Staff has been check all equipment at Rio Del Oro lift station on a regular basis. New carbon filter have been purchased and ready to be put in first sign of any odors. The manhole just north of the station has been rehabbed and lined, because of gas problems eroding away the interior.
- Staff has started to put more work into looking for I&I problems with the collection system. They have found several and we are addressing them as we find them. We purchased a new type of patch for fixing the main lines I&I issues because of cracks or offset that might be leaking. Staff has already installed its first patch and it worked great. This spot fix system will help out tremendously with the I&I issues. We also have another type of fix as well it will be for manholes leaks. Staff fixed a man hole which had a very bad leak down by lift station 18.
- Estimated Plant processed for the month of July was 51.33 MG.