

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : October 24, 2023

TO : John Tillotson, General Manager

FROM: Nicholas Pomeroy, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 11/16/2023**

- For the month of September the Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit.
- Plant Staff cleaned the filters and the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station: Staff has been checking all equipment at Rio Del Oro lift station on a regular basis.
- Lift Station 14: Staff has been water flushing once a week at lift station 18. This has been very positive. The H2S numbers have dropped dramatically and stabilized. Staff believes that the main cause has been found and that is the force main going under the Highway 70. So by flushing lift station 18 it keeps the H2S (odors) down.
- Staff has had to put work into looking for I&I problems with the collection system on hold because of Staff is gearing up to commence cleaning the collection system down in Plumas Lake area.
- On October 20th there was a Compliance Evaluation Inspection performed by the State. I am still awaiting the final report, but I believe everything went smooth and there are no violations to report.
- The Waste Water Plant processed for the month of September was 44.46 million gallons, which is an average of 1.48 MGD flow.

If you have any questions my contact info is below.

Nicholas Pomeroy

Chief Plant Operator
Olivehurst Public Utility District
Phone (530) 743-0843
Cell (530) 635-8113
email: npomeroy@opud.org