

OLIVEHURST PUBLIC UTILITY DISTRICT, 2026

To: John Tillotson

From Virgil Willard

Re: Monthly Report on Activities July 2026

1. Water Treatment Plants / Wells:

- WTP #4 / Well #1 – No operating issue. July total: 17.708 MG
- WTP #28 / Well #10 – No operating issues. July total: 20.459 MG
- Wheeler Ranch WTP Well #29 and #30 – No operating issues. July total: 62.374 MG
- Lindhurst Booster Pump Station – No operating issues.
- Plumas Lake WTP Well #31 and Well #32 – No operating issues. July total: 89.550 MG
- WTP #34 – The plant is online with no operating issues. July total: 9.672 MG

2.

Total MG	2018	2019	2020	2021	2022	2023	2024	2025	2026
Jan	49.5	49.3	52.7	62.0	59.7	62.7	61.71	66.78	65.23
Feb	47.25	44.8	56.2	57.4	68.8	64.25	56.04	58.05	60.79
Mar	51.2	52.9	74.2	74.5	109.9	61.89	68.16	72.12	101.06
Apr	65.1	70.0	93.8	114.5	101.3	81.61	86.31	101.52	106.93
May	116.9	104.3	142.2	162.6	140	124.93	143.2	161.38	131.16
Jun	151.8	151.5	165.4	162.4	157	155.39	189.5	188.60	183.22
Jul	171.4	168.3	186.9	182.2	185	190.12	203.5	212.42	199.76
Aug	152.1	170.9	176.9	165.5	102	188.11	181.2	184.53	
Sep	131.2	136.8	145.0	147.6	144	154.01	163.5	160.48	
Oct	105.2	117.2	132.3	109.3	125	117.66	148.0	109.01	
Nov	80.7	91.2	83.3	62.2	42	82.658	80.90	72.589	
Dec	53.5	60.5	62.3	58.3	62	71.571	76.46	56.064	

The pumping report will be a month behind

3.

Water Wells	Static July	Static August	Op July	Op August	Setting	GPM
Well #1	28ft	42ft	46ft	56ft	140ft	1500
Well #4	30ft	52ft	150ft	76ft	140ft	2340
Well #10	31ft	30ft	70ft	66ft	160ft	1500
Well #28	30ft	30ft	155ft	44ft	200ft	1100
Well #29	38ft	39ft	190ft	185ft	252ft	2400
Well #30	35ft	32ft	110ft	112ft	190ft	2700
Well #31	27ft	28ft	28ft	30ft	330ft	2450
Well #32	44ft	42ft	140ft	145ft	180ft	2920
Well #34	24ft	26ft	74ft	68ft	200ft	1600

4. For the month of July and August the distribution system and water treatment plants met all requirements.

5. Water Distribution Repairs

6. Radio Read Meters

- 40 meter locations on MXUs have been tested and repaired
- 0 flow checks evaluated and discussed with customers

Below is a list of repairs/expenditures recognizing failure after the monthly meter read.

August meter repair is \$66,250. The meter expenditure will be an addition to all monthly Water Department reports.

- 150 locations on Non-Consumption list repaired as necessary
- 395 MXU replaced (395 x \$165) = \$65,175
- 10 registers replaced (10 x \$75.00) = \$750
- 25 chambers replaced (25 x \$40.00) = \$1,000

7. Meter Program 0 flat rate services.

8. Water service shut off for non-payment – 96

9. District Subdivision and other projects

- a. July/August finals:
 - Plumas Lake – 24
 - Olivehurst – 4