

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : April 26, 2019

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 5/16/2018**

- For the month of March the Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit.
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; There has been no complaints since the carbon filters on the mini phoenix were replaced to try and help with possible odors from it. We also started adding a floating degreaser that has a strong citrus odor to it to help with possible odors from the wet well. Staff does check all equipment at Rio Del Oro lift station on a regular basis. New carbon filter have been purchased and ready to be put in first sign of any odors.
- Staff has started to put more work into looking for I&I problems with the collection system. They have found several and we are addressing them as we find them.
- Estimated Plant processed for the month of March was 79.05 MG.