

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : October 30, 2020

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 11/19/2020**

- For the month of September the Wastewater Treatment Facility had two exceedances of its N.P.D.E.S. permit. There was an illegal dump to the Collection system that caused a high NTU of 10 exceedance. It is not a category one exceedance so there is no fine attached. Staff has change some alarm settings that should help prevent this exceedance in the future. Also there was a Bactie (total coliform) measuring 7.8. The UV system was cleaned right after that in case that might have been the problem.
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; Staff has been check all equipment at Rio Del Oro lift station on a regular basis.
- Staff is continuing to put work into looking for I&I problems with the collection system. At this time most of that work is being done on new systems down south in the Plumas Lake area.
- Estimated Plant processed for the month of September was 56.4 MG.