

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : June 24, 2021

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 7/15/2021**

- For the month of June the Wastewater Treatment Facility had one exceedances of its N.P.D.E.S. permit. 275 MPN/100 seven day median Permit is 2.2. This was believed to be caused by an Operator possibly not disinfecting the sampling equipment properly. This something that the Operator doesn't normally do and wasn't familiar with doing. The Operator was filling in for the Lab Tech that was on vacation. The Lab tech will be giving the Operators refresher course on how to sample the Bactie.
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; Staff has been check all equipment at Rio Del Oro lift station on a regular basis. The blower unit on the mini phoenix has been fixed and is back up and running.
- Staff is continuing to put work into looking for I&I problems with the collection system. At this time most of that work is being done on the old systems here in Olivehurst area. Repairs are being done as the County proceeds with doing the road over lays. 11th street has started and we have 5 repairs being done there. This project is still being worked on.
- Estimated Plant processed for the month of June was 42.49 MG.