

# OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : July 29, 2022

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 8/18/2022**

---

- For the month of July, the Wastewater Treatment Facility had one exceedances of its N.P.D.E.S. permit. Total coliform of 47 MPN, this was believed to be caused by particles in the water after cleaning the filters and restarting the system back-up too quickly.
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; Staff has been checking all equipment at Rio Del Oro lift station on a regular basis.
- The odor control project for lift station 14 (Zanes and River Oaks) was started on July 14<sup>th</sup>. So far not much has changed. But it is still early in the testing for the system to really see much change.
- Staff has had to put work into looking for I&I problems with the collection system on hold because of short Staff and workload on doing inspections for the District.
- Estimated Plant processed for the month of July was 42.1 MG.

**If you have any questions my contact info is below.**

***Gregory P. Axline***

Chief Plant Operator  
Olivehurst Public Utility District  
Phone (530) 743-0843  
Cell (530) 812-2270  
email: [gaxline@opud.org](mailto:gaxline@opud.org)