

OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : October 28, 2022

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 11/17/2022**

- For the month of September, the Wastewater Treatment Facility had no exceedances of its N.P.D.E.S. permit.
- Plant Staff cleaned the filters and the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; Staff has been checking all equipment at Rio Del Oro lift station on a regular basis.
- The odor control project for lift station 14 (Zanes and River Oaks) was started on July 14th, has been temporarily put on hold because of problems with Lift Station 18. 18 had to be worked on because of construction debris jamming up the pumps. This was fixed but the bug system is being moved to Lift Station 15. So, it will be closer to the problem and hopefully a quicker change in the amount of odors coming out at Lift station #14.
- Staff has had to put work into looking for I&I problems with the collection system on hold because of short Staff and workload on doing inspections for the District.
- Estimated Plant processed for the month of September was 38.43 MG.

If you have any questions my contact info is below.

Gregory P. Axline

Chief Plant Operator
Olivehurst Public Utility District
Phone (530) 743-0843
Cell (530) 812-2270
email: gaxline@opud.org