

OLIVEHURST PUBLIC UTILITY DISTRICT, 2026

To: John Tillotson

From: Virgil Willard

Re: Monthly Report on Activities May 2026

1. Water Treatment Plants / Wells:

- WTP #4 / Well #1 – No operating issue. May total: 0.027MG
- WTP #28 / Well #10 – No operating issues. May total: 8.068 MG
- Wheeler Ranch WTP Well #29 and #30 – No operating issues. May total: 57.986 MG
- Lindhurst Booster Pump Station – No operating issues.
- Plumas Lake WTP Well #31 and Well #32 – No operating issues. May total: 14.485 MG
- WTP #34 – The plant is online with no operating issues. May total: 50.598 MG

2.

Total MG	2018	2019	2020	2021	2022	2023	2024	2025	2026
Jan	49.5	49.3	52.7	62.0	59.7	62.7	61.71	66.78	65.23
Feb	47.25	44.8	56.2	57.4	68.8	64.25	56.04	58.05	60.79
Mar	51.2	52.9	74.2	74.5	109.9	61.89	68.16	72.12	101.06
Apr	65.1	70.0	93.8	114.5	101.3	81.61	86.31	101.52	106.93
May	116.9	104.3	142.2	162.6	140	124.93	143.2	161.38	131.16
Jun	151.8	151.5	165.4	162.4	157	155.39	189.5	188.60	
Jul	171.4	168.3	186.9	182.2	185	190.12	203.5	212.42	
Aug	152.1	170.9	176.9	165.5	102	188.11	181.2	184.53	
Sep	131.2	136.8	145.0	147.6	144	154.01	163.5	160.48	
Oct	105.2	117.2	132.3	109.3	125	117.66	148.0	109.01	
Nov	80.7	91.2	83.3	62.2	42	82.658	80.90	72.589	
Dec	53.5	60.5	62.3	58.3	62	71.571	76.46	56.064	

The pumping report will be a month behind

3.

Water Wells	Static May	Static June	Op May	Op June	Setting	GPM
Well #1	26ft	25ft	52ft	53ft	140ft	1500
Well #4	24ft	28ft	51ft	50ft	140ft	2240
Well #10	26ft	50ft	67ft	78ft	160ft	1500
Well #28	26ft	46ft	40ft	82ft	200ft	1100
Well #29	26ft	29ft	191ft	196ft	252ft	2500
Well #30	24ft	24ft	109ft	170ft	190ft	2850
Well #31	26ft	24ft	Naft	28ft	330ft	2400
Well #32	24ft	27ft	132ft	133ft	180ft	2940
Well #34	12ft	23ft	50ft	54ft	200ft	522

4. For the month of May and June the distribution system and water treatment plants met all requirements.
5. Water Distribution Repairs
6. Radio Read Meters:
 - 50 meter locations on MXUs have been tested and repaired
 - 0 flow checks evaluated and discussed with customers

Below is a list of repairs/expenditures recognizing failure after the monthly meter read. May meter repair is \$3,750. The meter expenditure will be an addition to all monthly Water Department reports.

- 0 locations on Non-Consumption list repaired as necessary
 - 20 MXU replaced (20 x \$165) = \$3,300
 - 6 registers replaced (6 x \$75.00) = \$450
 - 0 chambers replaced (0 x \$40.00) = \$0
7. Meter Program 0 flat rate services.
 8. Water service shut off for non-payment 97
 9. District Subdivision and other projects
 - a. May/June finals:
 - Plumas Lake – 24
 - Olivehurst – 4

