

# OLIVEHURST PUBLIC UTILITY DISTRICT MEMORANDUM



DATE : February 1, 2019

TO : John Tillotson, General Manager

FROM: Greg Axline, Chief Plant Operator

RE: **Monthly Report of Activities for Board meeting on 2/21/2018**

---

- For the month of January the Wastewater Treatment Facility had two exceedances three days in a row for NTU and UV transmittance of its permit. This was caused by the large storm that came through on the January 16<sup>th</sup>, 17<sup>th</sup> and 18<sup>th</sup>. The plant ran the whole month having all systems running well and efficiently the storm caused the exceedances.
- Plant Staff cleaned the filter panels and on the UV system to keep both systems running efficiently.
- Rio Del Oro Lift station; We are advancing our scheduling of flushing of the main lines in that area to try help with knocking down odors in that area. So far this seems to be working. Staff has been pulling H<sub>2</sub>s readings from the influent and discharge of the Mini Phoenix and we have seen a drop in the H<sub>2</sub>s gas levels. There has been no complaints since the carbon filters on the mini phoenix were replaced to try and help with possible odors from it. We also started adding a floating degreaser that has a strong citrus odor to it to help with possible odors from the wet well.
- Estimated Plant processed for the month of December was 56.73 MG.